

APPENDIX 5

Pt. 150, App. A

14 CFR Ch. I (1-1-98 Edition)

TABLE 1—LAND USE COMPATIBILITY* WITH YEARLY DAY-NIGHT AVERAGE SOUND LEVELS

Land use	Yearly day-night average sound level (L _{dn}) in decibels					
	Below 65	65-70	70-75	75-80	80-85	Over 85
RESIDENTIAL						
Residential, other than mobile homes and transient lodgings.	Y	N(1)	N(1)	N	N	N
Mobile home parks _____	Y	N	N	N	N	N
Transient lodgings _____	Y	N(1)	N(1)	N(1)	N	N
PUBLIC USE						
Schools _____	Y	N(1)	N(1)	N	N	N
Hospitals and nursing homes _____	Y	25	30	N	N	N
Churches, auditoriums, and concert halls _____	Y	25	30	N	N	N
Governmental services _____	Y	Y	25	30	N	N
Transportation _____	Y	Y	Y(2)	Y(3)	Y(4)	Y(4)
Parking _____	Y	Y	Y(2)	Y(3)	Y(4)	N
COMMERCIAL USE						
Offices, business and professional _____	Y	Y	25	30	N	N
Wholesale and retail—building materials, hardware and farm equipment.	Y	Y	Y(2)	Y(3)	Y(4)	N
Retail trade—general _____	Y	Y	25	30	N	N
Utilities _____	Y	Y	Y(2)	Y(3)	Y(4)	N
Communication _____	Y	Y	25	30	N	N
MANUFACTURING AND PRODUCTION						
Manufacturing, general _____	Y	Y	Y(2)	Y(3)	Y(4)	N
Photographic and optical _____	Y	Y	25	30	N	N
Agriculture (except livestock) and forestry _____	Y	Y(6)	Y(7)	Y(8)	Y(8)	Y(8)
Livestock farming and breeding _____	Y	Y(6)	Y(7)	N	N	N
Mining and fishing, resource production and extraction.	Y	Y	Y	Y	Y	Y
RECREATIONAL						
Outdoor sports arenas and spectator sports _____	Y	Y(5)	Y(5)	N	N	N
Outdoor music shells, amphitheaters _____	Y	N	N	N	N	N
Nature exhibits and zoos _____	Y	Y	N	N	N	N
Amusements, parks, resorts and camps _____	Y	Y	Y	N	N	N
Golf courses, riding stables and water recreation.	Y	Y	25	30	N	N

Numbers in parentheses refer to notes.

*The designations contained in this table do not constitute a Federal determination that any use of land covered by the program is acceptable or unacceptable under Federal, State, or local law. The responsibility for determining the acceptable and permissible land uses and the relationship between specific properties and specific noise contours rests with the local authorities. FAA determinations under part 150 are not intended to substitute federally determined land uses for those determined to be appropriate by local authorities in response to locally determined needs and values in achieving noise compatible land uses.

KEY TO TABLE 1

SLUCM—Standard Land Use Coding Manual.

Y (Yes)—Land Use and related structures compatible without restrictions.

N (No)—Land Use and related structures are not compatible and should be prohibited.

NLR—Noise Level Reduction (outdoor to indoor) to be achieved through incorporation of noise attenuation into the design and construction of the structure.

25, 30, or 35—Land use and related structures generally compatible; measures to achieve NLR of 25, 30, or 35 dB must be incorporated into design and construction of structure.

NOTES FOR TABLE 1

- (1) Where the community determines that residential or school uses must be allowed, measures to achieve outdoor to indoor Noise Level Reduction (NLR) of at least 25 dB and 30 dB should be incorporated into building codes and be considered in individual approvals. Normal residential construction can be expected to provide a NLR of 20 dB, thus, the reduction requirements are often stated as 5, 10 or 15 dB over standard construction and normally assume mechanical ventilation and closed windows year round. However, the use of NLR criteria will not eliminate outdoor noise problems.
- (2) Measures to achieve NLR 25 dB must be incorporated into the design and construction of portions of these buildings where the public is received, office areas, noise sensitive areas or where the normal noise level is low.
- (3) Measures to achieve NLR of 30 dB must be incorporated into the design and construction of portions of these buildings where the public is received, office areas, noise sensitive areas or where the normal noise level is low.
- (4) Measures to achieve NLR 35 dB must be incorporated into the design and construction of portions of these buildings where the public is received, office areas, noise sensitive areas or where the normal level is low.
- (5) Land use compatible provided special sound reinforcement systems are installed.
- (6) Residential buildings require an NLR of 25.
- (7) Residential buildings require an NLR of 30.
- (8) Residential buildings not permitted.